

Texas Department of State Health Services

PO BOX 149347 AUSTIN, TEXAS 78714-9347 1-888-963-7111 www.dshs.state.tx.us

LABORATORY SERVICES SECTION, MC-1947 1100 W. 49th St., Austin, Tx. 78756 (512)458-7587

EPA 552.2 Haloacetic Acids Analysis Report

Submitter Identification Number: 0260006

BIRCH CREEK RECREATION WSC

JAHN, RAY 472 BARBARA

SOMERVILLE, TX 77879-6382

Date Reported: 04/02/2024

Report ID#: 20240402125531AG77450

Lab Sample ID# # AG77450 Sample Priority: NORMAL

TCEQ ID#(s): 2443109

Water Source :

Entry Point(s): DBP2-01

Date Collected: 03/14/2024 10:24

Conc. Units: µg/L

Date Received: 03/15/2024 Date Analyzed: 03/23/2024 Method: 552.2 Rev 1.0 Analyst: BF

Extraction Date: 03/21/2024

Sample Cond.: Acceptable

Regulated Compounds	Result	Qualifier
Monochloroacetic acid	<2.0	
Dichloroacetic acid	1.0	
Trichloroacetic acid	<1.0	
Monobromoacetic acid	<1.0	
Dibromoacetic acid	2.6	
Total HAA5 ¹	3.6	
Monitored Compounds	Result	Qualifier
Bromochloroacetic acid	1.2	
Dalapon	<1.0	
Comments:		

The test results on this report relate only to the sample identified on this report. The test results for analytes noted(1) meet all TNI (2016 Standard) requirements.

Authorized by Group Manager AVINYARD on 04/01/2024