

LABORATORY SERVICES SECTION, MC-1947
1100 W. 49th St., Austin, Tx. 78756 (512)458-7587

**EPA 552.2 Haloacetic Acids
Analysis Report**

Submitter Identification Number: 0260006

BIRCH CREEK RECREATION WSC
JAHN, RAY
472 BARBARA
SOMERVILLE, TX 77879-6382

Date Reported : 10/19/2023

Report ID# : 20231019090218AG56209

Lab Sample ID# : AG56209
Sample Priority : NORMAL
TCEQ ID#(s) : 2354921

Water Source :
Entry Point(s) : DBP2-01

Date Collected : 09/14/2023 11:47
Date Received : 09/15/2023
Date Analyzed : 09/26/2023
Extraction Date : 09/22/2023

Conc. Units : µg/L
Method : 552.2 Rev 1.0
Analyst : JL
Sample Cond. : Acceptable

Regulated Compounds	Result	Qualifier
Monochloroacetic acid	<2.0	
Dichloroacetic acid	<1.0	
Trichloroacetic acid	<1.0	
Monobromoacetic acid	<1.0	
Dibromoacetic acid	5.9	
Total HAA5 ¹	5.9	
Monitored Compounds	Result	Qualifier
Bromochloroacetic acid	1.5	
Dalapon	<1.0	

Comments:

EPA Method 552.2-- data is suspect because surrogate recovery was above method acceptance limits. The test results on this report relate only to the sample identified on this report. The test results for analytes noted(') meet all TNI (2016 Standard) requirements.

Authorized by Branch Manager TDUNN on 10/18/2023